



Clayton County HD Building October 31, 2006

Introduction

On October 19, 2006, a representative from the Georgia Environmental Protections Division (GEPD), Lead Paint and Asbestos Program, provided a consultation regarding the Clayton County Health Department Office Building. The goal was to help determine if additional investigation and/or sampling was recommended to ensure that all asbestos-containing materials have been properly abated.

Conclusions

After performing an informal inspection of the facility and reviewing asbestos abatement records, GEPD concluded that potential sources of remaining asbestos are most likely limited to:

- Floor linoleum backing in warehouse area
- Floor filler in warehouse area

- Dust and debris in mezzanines
- Roll roof or tar paper edges and roof penetration areas closest to ceilings throughout building
- Transit wall areas
- Furnaces (in closed off room and roof) from former operations
- Water chillers with asbestos panels

Recommendations

Based on the conclusions provided by GEPD, the above materials should be investigated and/or sampled further for asbestos by a licensed contractor.