

TEST W-33 ITEMS TESTED	MAXIMUM CONTAMINANT LEVEL (mg/l)	FREQUENCY OF TESTING
pH	<6.5	annually
phosphorus (P)	-	annually
Potassium (K)	-	annually
Calcium (Ca)	-	annually
Magnesium (Mg)	-	annually
Manganese (Mn)	0.05	annually
Iron (Fe)	0.3	annually
Aluminum (Al)	0.05 - 0.2	annually
Boron (B)	-	annually
Copper (Cu)	1	annually
Zinc (Zn)	5	annually
Sodium (Na)	-	annually
Chromium (Cr)	0.1	annually
Cadmium (Cd)	0.005	annually
Nickel (Ni)	0.1	annually
Molybdenum (Mo)	-	annually
*- hardness	-	annually
sulfate (SO <sub>4</sub> )	250	annually
Nitrate (NO <sub>3</sub> )	45	annually
Chloride (Cl)	250	annually
Soluble Salts		annually
Alkalinity	-	annually
Carbon dioxide (CO <sub>2</sub> )	-	annually
Nitrate - Nitrogen (NO <sub>3</sub> -N)	10	annually
Nitrite- Nitrogen (NO <sub>2</sub> -N)	1	annually
TDS (Total Dissolved Solids)	500	annually
Color	15 color units	annually
Turbidity	5 units	annually
Total Nitrate (NO <sub>3</sub> +NO <sub>2</sub> as N)	10 (as N)	annually
Total Coliform	presence or absence	quarterly
Fecal Coliform	presence or absence	quarterly